

Seattle Fire Department Permit Application
Code 3001 Outdoor Storage of Finished Lumber

Level I
--Revised 1/2005--



Permit Fee: \$118.00

TO BE COMPLETED BY PERMIT APPLICANT (PLEASE PRINT)

FIRM NAME		
MAILING ADDRESS	SUITE	
CITY	STATE	ZIP
OPERATION ADDRESS		
CONTACT PERSON	PHONE NUMBER ()	
Please include a check made payable to the CITY OF SEATTLE with this application.		

Permit applications may be submitted in person weekdays from 8:00 a.m. to 4:30 p.m., or mailed to:

Seattle Fire Department
Fire Marshal's Office—Permits
220 Third Avenue South, Second Floor
Seattle, WA 98104-2608

Permit processing: (206) 386-1025
www.seattle.gov/fire

TO BE COMPLETED BY INSPECTING ENGINE/LADDER COMPANY:

TYPE OF MATERIAL	AMOUNT	LOCATION
Example: Finished Lumber	3,000 cubic feet	NE corner of main yard
<input type="checkbox"/> Permit Conditions Approved		
Inspected By:	C/P/O:	SFD ID#:
Station No.	Occ. No.:	Date:
Special Permit Conditions: (continue on back if necessary)		

FMO OFFICE USE ONLY:

Date Received:	Receipt No.:	Check No.:
Expiration Date with Existing Permits:		Application ID#
<input type="checkbox"/> Cancel with full refund <input type="checkbox"/> Cancel, no refund <input type="checkbox"/> Moved <input type="checkbox"/> No Longer Needs <input type="checkbox"/> Out of Business		

PERMIT CONDITIONS:

1. Outside storage of lumber shall not be located within 10 feet of a property line. (2003 SFC 315.3)
Exception: The separation distance is allowed to be reduced 3 feet for storage not exceeding 6 feet in height.
2. Lumber stored or displayed outside of buildings that are protected by automatic sprinklers shall not be stored or displayed under nonsprinklered eaves, canopies, or other projections or overhangs. (2003 SFC 315.3.1)
3. Storage in the open shall not exceed 20 feet in height. (2003 SFC 315.3.2)
4. Exterior lumber storage shall form stable piles with a maximum height of 20 feet. Piles shall not exceed 150,000 cubic feet in volume. (2003 SFC 1909.2)
5. Fire apparatus access lanes between lumber piles shall be at least 20 feet wide and shall be maintained free from accumulation of rubbish, equipment and other articles or materials. (2003 SFC Appendix D)
6. Approved "NO SMOKING" signs shall be conspicuously posted and maintained in buildings and areas where lumber is stored or handled. (2003 SFC 310.2 and 310.3)
7. Permanent lumber storage areas shall be surrounded with an approved fence at least 6 feet high, unless storage is within a building. (2003 SFC 1909.4)
8. Portable extinguishers having a minimum rating of 2A:20B shall be located so that the travel distance to the nearest extinguisher does not exceed 75 feet. (2003 SFC 1909.5)